

# Monthly Analysis Report


May 2024



\$3,610



\$0



● É.s.c. Champlain ● École publique de la Découverte ● École St-Denis

● É.s.c. Champlain ● École publique de la Découverte ● École St-Denis

\*\* This chart shows sites with the highest production

\*\*This chart shows sites with largest loss

## Executive

This portfolio although small has been performing quite well. Would appear nominal performance in May 2024 would be 140 to 150kWh/DC kW

École publique de la Découverte  
Possible a string failed in 2022 resulting in lower performance.

École St-Denis  
Appears the inverter stopped producing August 3rd 2024 and last readings were from August 6th

Site	<a href="#">Click for Portal</a>	DC Size	Revenue	Production	Losses
É.s.c. Champlain		11kW	\$1,323	1,649kWh 150kWh/kW	\$0 0%
École publique de la Découverte		11kW	\$1,028	1,281kWh 116kWh/kW	\$0 0%
École St-Denis		11kW	\$1,259	1,570kWh 143kWh/kW	\$0 0%
<b>Total</b>			<b>\$3,610</b>	<b>4,501kWh</b>	<b>\$0 0%</b>