



\$

\$63,212



\$0



** This chart shows sites with the highest production

**This chart shows sites with largest loss

Executive

All systems are central inverters installed in 2013 and were working well and consistent in their performance. Two systems though throughout the year did experience problems resulting in them being offline for a number of weeks.

Site	Click for Portal	DC Size	Revenue	Production	Losses
EMS Headquarters		58kW	\$4,645	7,873kWh 135kWh/kW	\$0 0%
FW Transit Building		130kW	\$10,698	18,133kWh 139kWh/kW	\$0 0%
Mounddale Maintenance Garage		90kW	\$7,318	12,403kWh 138kWh/kW	\$0 0%
Port Arthur Arena		104kW	\$8,946	15,163kWh 146kWh/kW	\$0 0%
TbayTel Work Centre		120kW	\$10,082	17,087kWh 142kWh/kW	\$0 0%
Victoriaville Parkade Thunder Bay		280kW	\$21,523	36,480kWh 131kWh/kW	\$0 0%
Total			\$63,212	107,139kWh	\$0 0%